

TOSHIBA 4200FA CT/XT UPS

Installation Planning Guide for 15-80kVA UPS

Standard System: 208/120V Input, 208/120V Output

General Mechanical Information			
UPS kVA/ kW Rating	Dimensions (W x D x H)	Weight	Approximate Full-Load Heat Loss
	Inches	Lbs.	kBtu/Hr
15 kVA/12 kW	20 x 36.3 x 59.7	900	9
25 kVA/ 20 kW	20 x 36.3 x 59.7	910	12
30 kVA/ 24 kW	20 x 36.3 x 59.7	915	14.4
50 kVA/ 40 kW	35.5 x 38.3x 59.3	2,548	18.6
80 kVA/ 64 kW	44 x 31 x 74	1,560*	27

Primary AC Input (208/120V 3-Phase / 4-Wire)					
Maximum Input Power Demand			Suggested External Feeder Breaker	Suggested Minimum Feeder Wire Size Per Phase / Neutral	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kVA	PF	Amps	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
15	>0.97	45	60 A	(1) x 6 / (1) x 4	380
25	>0.97	70	90 A	(1) x 3 / (1) x 1	380
30	>0.97	83	110 A	(1) x 2 / (1) x 1	380
50	>0.97	138	175 A	(1) x 2/0 / (1) 250	380
80*	>0.97	218	300 A	(1) x 300 / (1) x 500	380

Optional Alternate AC Input (208/120V 3-Phase / 4-Wire)					
Maximum Input Power Demand			Suggested External Feeder Breaker	Suggested Minimum Feeder Wire Size Per Phase / Neutral	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kVA	PF	Amps	Amps	AWG at 75° C Temp. Rating	Feet
15	>0.97	39	60 A	(1) x 6 / (1) x 4	380
25	>0.97	65	90 A	(1) x 3 / (1) x 1	380
30	>0.97	78	110 A	(1) x 2 / (1) x 1	380
50	>0.97	131	175 A	(1) x 2/0 / (1) 250	380
80*	>0.97	209	300 A	(1) x 300 / (1) x 400	380

Battery Input (288VDC Nominal)					
Battery Capacity Required for Full Load Output		Maximum Discharge at Full Load Output	Suggested External Feeder Breaker	Suggested Minimum Feeder Wire Size Per Phase	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
	kWB	Amps DC	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
15	14	61	70 A	(1) x 4	70
25	23	100	100 A	(1) x 1	70
30	28	120	125 A	(1) x 1	70
50	45	195	200 A	(1) x 250	70
80*	73	316	350 A	(2) x 4/0	70

AC Output (208/120V 3-Phase / 4-Wire)					
Rated Output Power			Suggested External Feeder Breaker	Suggested Minimum Feeder Wire Size Per Phase / Neutral	Suggested Maximum Feeder Length For Min. Wire Size in Steel Conduit
kVA	PF	Amps	Amps	AWG or kcmil at 75° C Temp. Rating	Feet
15	0.8	39	60 A	(1) x 6 / (1) x 4	380
25	0.8	65	90 A	(1) x 3 / (1) x 1	380
30	0.8	78	110 A	(1) x 2 / (1) x 1	380
50	0.8	131	175 A	(1) x 2/0 / (1) 250	380
80*	0.8	209	300 A	(1) x 300 / (1) x 400	380

* 80kVA UPS uses external battery cabinet, and has no internal transformers.

TOSHIBA 4200FA CT/XT UPS

Installation Planning Guide for 15-80kVA UPS

Standard System: 208/120V Input, 208/120V Output

Important Notes:

1. Maximum Current required at Primary AC Input based on full load output and maximum battery charging current.
2. Output load conductors are to be installed in separate conduit from input conductors.
3. Control wires and power wires are to be installed in separate conduits.
4. Recommended AC input and output overcurrent protection based on continuous full load current per NEC.
5. Wiring shall comply with all applicable national and local electrical codes.
6. Grounding conductors to be sized per NEC Article 250-122. Neutral conductors to be sized per NEC Article 310.15.
 - Primary AC Input: 3 ϕ , 3-wire + ground.
 - AC Output: 3 ϕ , 4-wire + ground.
 - DC Input: 2-wire (Positive/Negative) + ground.
7. Power cable maximum size:
 - 15/25/30kVA: #1 AWG
 - 50kVA: 250 kcmil
 - 80kVA: 500 kcmil, Battery Terminals – 600 kcmil
8. Nominal battery voltage based on the use of VRLA type batteries (2.0 volts / cell nominal).
9. Maximum battery discharge current based on lowest permissible discharge voltage of 1.6 VPC.
10. DC wires should be sized to allow not more than a 2-volt drop at maximum discharge current.
11. Weights include internal batteries.
12. Sizing calculations based on the following assumptions:
 - Not more than 3 current-carrying conductors installed in steel conduit in ambient temperature of 30 degrees C.
 - Temperature rating of conductors and terminals: 75 deg. C.
 - Feeder distance calculations based on NEC Tables 8 and 9 data, allowing for 2% AC voltage drop.
 - Reference: 2002 NEC Handbook. Consult latest edition of applicable national and local codes for possible variations.
13. Ratings of wires and overcurrent devices are suggested minimums. Consult with a registered Professional Engineer within your local area for proper size selections.

TOSHIBA INTERNATIONAL CORPORATION

13131 West Little York Road
Houston, TX 77041
Telephone: 800.231.1412; 713.466.0277
Fax: 713.896.5212
Corporate Web Site: www.tic.toshiba.com
Group Web Site: www.toshibaups.com